

UNITED STATES GOVERNMENT

Memorandum

TO : Commander, Coast Guard Section, Philippines

DATE: 2 August 1971

FROM : Chief, Engineering and Maintenance Section

SUBJECT: Power Units; condition of

1. Loran Station Batan

- a. Engine No. 1 Serial No. 6923
Gen. 20 KW 25 KVA
Condition: Good. Engine has 1,951.3 hours.
- b. Engine No. 2 Serial No. 8158
Gen. 20KW 25 KVA
Condition: Good. Front bearing needs replacing.
Engine has 10,183 hours.
- c. Engine No. 3 Serial No. 6359
Gen. 20 KW 25 KVA
Condition: Good
Engine has 14,928 hours.
- d. Engine No. 4 Serial No. 6572
Gen. 20 KW 25 KVA
Condition: Good. Engine has 13,104 hours.
- e. Spare Engine No. 1
Gen. 20 KW 25 KVA
Condition: Excellent. No hours.
- f. Spare Engine No. 2
Gen. 20 KW 25 KVA
Condition: Excellent. No hours.

2. Loran Station Catanduanes Eng hrs. as of 3/14/71

- a. Engine No. 1
Gen. 20 KW 25 KVA
Condition: Excellent. Engine hours, 191.0
- b. Engine No. 2 Serial No. 6320
Gen. 20 KW 25 KVA
Condition: Excellent. Engine hrs.: 3



2 August 1971

Subj: Power Units; condition of

c. Engine No. 3 Serial No. 6575
Gen. 20 KW 25 KVA
Condition: Excellent. Engine hours: 49

d. Engine No. 4 Serial No. 5321
Gen. 20 KW 25 KVA
Condition: Excellent. Engine Hours: 1.5

e. Station has no spare.

f. ~~PCG has one spare engine for Catanduanes.~~ *PHILIPPINE COAST GUARD HAS RECEIVED ONE SPARE ENGINE FOR DELIVERY TO CATANDUANES.* Engine condition, excellent. No hours.

3. Loran Station Talampulan

a. Engine No. 1 Serial No. 16392
Gen. 20 KW 25 KVA
Condition: Good. Engine has 29,154 hours.

b. Engine No. 2 Serial No. 6510
Gen. 20 KW 25 KVA
Condition: Good. Engine hrs.: 32,387
Front bearing needs replacing.

c. Engine No. 3 Serial No. 5514
Gen. 20 KW 25 KVA
Condition: Good. Engine hrs.: 8,889

d. Engine No. 4 Serial No. 6295
Gen. 20 KW 25 KVA
Condition: Good. Engine hrs.: 24,349

e. Spare Engine
Gen. 20 KW 25 KVA
Condition: Excellent. No hours.

4. Loran Station Tarumpitao

a. Engine No. 1 Serial 8680
Gen. 20 KW 25 KVA
Condition: Good. Engine hrs.: 14,531

b. Engine No. 2 Serial No. 8566
Gen. 20 KW 25 KVA
Condition: Good. Engine hrs.: 4,042

c. Engine No. 3 Serial No. 7503
Gen. 20 KW 25 KVA
Condition: Good. Engine hrs.: 16,612

2 August 1971

Subj: Power Units; condition of

- d. Engine No. 4 Serial No. 8683
Gen. 20 KW 25 KVA
Condition: Good. Engine hrs.: 5,829
 - e. Spare Engine
Gen. 20 KW 25 KVA
Condition: Excellent. No hours.
5. Loran Station Naulo Point
- a. Engine No. 1 Serial 5524
Gen. 20 KW 25 KVA
Condition: Good. Engine hrs.: 18,340
 - b. Engine No. 2 Serial 7300
Gen. 20 KW 25 KVA
Condition: Fair. Engine hrs.: 25,031
5,000 hr. overhaul due.
 - c. Engine No. 3 Serial 6224
Gen. 20 KW 25 KVA
Condition: Good. Engine hrs.: 16,675
 - d. Engine No. 4 Serial 6237
Gen. 20 KW 25 KVA
Condition: Good. Engine hrs.: 10,656
 - e. Spare Engine
Gen. 20 KW 25 KVA
Condition: Excellent. No hours.
6. Spare engine at Cavite Naval Base has just been overhauled.
Gen. 20 KW 25 KVA
Condition: Excellent. No hours.

A. N. Smollan
For
R. C. PIERCE